



## Detailed Quality Summary Report

Plant MT HOLLY  
 Product MT HOLLY SUBBASE  
 Specification NJDOT - RCA DGABC  
 Period 1/1/26 - PRESENT

Sieve / Test	Results	Specification
1 1/2" ( 37.5mm)	100.0	100
1" (25mm)	96.1	
3/4" (19mm)	84.5	55 / 90
3/8" ( 9.5mm)	49.7	
#4 (4.75mm)	42.6	25 / 50
#8 (2.36mm)	36.6	
#50 ( .300um)	15.8	5 / 20
#200 (.075 um)	5.8	3 / 10

Other Test Results

**AASHTO T-99 Method C**  
**Max Dry Density 121.4 lbs. / cubic ft**  
**Optimal Moisture Percentage 11.5**

